



## **FEATURES**

- > AC 100-240V Wide-range Input.
- > Cost optimized without compromising quality or reliability.
- ➤ Full power between -25°C and +50°C.
- Compact size.

## INTENDED USE

This device is designed for installation in an enclosure and is intended for the general professional use such as in instrumentation equipment, office, industrial control and communication.

Do not use this power supply in equipment where malfunction may cause severe personal injury or threaten human life.

INPUT SPECIFICATIONS	
INPUT VOLTAGE RANGE	100 - 240VAC ±10% ; 127 - 370VDC
FREQUENCY RANGE	50-60Hz
EFFICIENCY(TYP.)	>87% @ 230VAC
AC CURRENT(TYP.)	1.2A @ 115VAC; 0.8A @ 230VAC
INRUSH CURRENT(TYP.)	<48Amps; Measured at 264VAC, 25°C Ambient, Cold Start
START UP TIME	<1 Sec@ 230VAC & <3 Sec@115VAC, Full Load


OUTPUT SPECIFICATION	OUTPUT SPECIFICATIONS	
OUTPUT VOLTAGE	24 - 28VDC	
OUTPUT CURRENT	2.5A at 24V; 2.14A at 28V	
RIPPLE AND NOISE	<1% of Vout ★	
LINE AND LOAD REGULATION	±1%	
HOLD UP TIME	≥60ms at 230VAC & ≥15ms at 115VAC, Full Load	
SERIES OPERATION	Possible for up to two power supplies (with external diode)	


★ Ripple & Noise measured at 20MHz of bandwidth by using 0.1uF & 10uF parallel capacitor.

PROTECTIONS	
INPUT FUSED	2A - 250VAC Internal
OUTPUT OVER LOAD	≥110% of rated output current Protection type : Hiccup mode; recovers automatically after fault condition is removed.
OUTPUT SHORT CIRCUIT	Hiccup mode when output is shorted; Recovers automatically after fault condition is removed.
OUTPUT OVER VOLTAGE	31.5VDC ± 1VDC Protection type : Latched; Input AC power has to be recycled to recover the power supply.
OVER TEMPERATURE	Power supply shuts down when the temperature of PCB below main transformer reaches typically 120°C; Turns on only after the temperature falls below 90°C typically and AC power is recycled there after .


ENVIRONMENT	
OPERATING TEMPERATURE	-25°C to +70°C *De-rate output power at 1.5W/°C above +50°C Ambient.
STORAGE TEMPERATURE	-40°C to +85°C.
HUMIDITY	5 to 95% RH, Non Condensing
ALTITUDE	2000m

SAFETY & EMC	
SAFETY STANDARDS	Designed to meet IEC 62368-1 Processing for UL-508
DIELECTRIC WITHSTAND VOLTAGE	I/P to Earth : 2500VAC I/P to O/P : 4000VAC O/P to Earth : 1500VAC
INSULATION RESISTANCE	100 $M\Omega$ min. (between all outputs and all inputs/ PE terminals) at 500 VDC
CONDUCTED EMISSION	EN55022 ; Class A
RADIATED EMISSION	EN55022 ; Class A
EMS IMMUNITY	Compliance to IEC61000-4-4,5,11






## WIRING DIAGRAM





## WIRING INSTRUCTIONS

- 1. To prevent risk of electric shock, power supply equipment must be kept OFF while wiring.
- 2. Terminals and electrically charged parts must not be touched when the power is ON.
- 3. Wiring shall be done strictly according to terminal layout provided in the operating manual.

Doc. name: OP INST RPS60-24-CU OP1041-V01(Page 1 of 2)







## INSTALLATION INSTRUCTIONS

## Attention:(Fig. 1)

- 1. Do not block the ventilation holes of power supply.
- 2. Keep at least 20mm clearance around the switching power supply.
- 3. The Equipment should not be installed in environmental conditions other than those specified in this manual.

## Mounting:(Fig.2)

- 1. Slightly tilt the unit to engage on the top side of Din Rail mounting.
- 2. Press it downward until it gets locked in Din Rail.

#### Removal:(Fig.3)


- Before removing power supply unit from Din Rail ensure that supply has been switched off.
- 2. Unscrew all the wire connections of power supply unit.
- Insert a screw driver into the mounting clamp slot & pull it down to remove the power supply from Din Rail.

## **↑** WARNING:


#### Risk of electrical shock, fire, personal injury or death.

- Do not use the power supply without proper grounding (Protective Earth).
- Do not use in wet locations or in areas where moisture or condensation can be expected.
- Make sure mains power supply is off before wiring the power supply unit. Make sure of correct wiring. Incorrect wiring may cause electrical shock or damage.
- Do not touch the power supply during operation or immediately after turning off because some parts get hot or are at high voltage which may cause burns or electrical shock.
- Do not install the power supply where human body may come into contact while power is supplied to the power supply.
- Do not repair the power supply at user end . Modification or repairing of the power supply by users may cause electrical shocks, damage, & other accidents.
- If damage or malfunction occurs during operation, immediately turn off mains power.

## **A** CAUTION



## **MEANING OF PRODUCT SAFETY SYMBOL**



#### **SAFETY INSTRUCTIONS**

- > This manual is meant for personnel involved in wiring installation operation & routine maintenance of the equipment.
- Disconnect power supply of your system before starting any installation operation or wiring.
- Improper installation operation or wiring may impair safety & failure of the unit or electrical shock or damage.
- Connect the ground completely. A protective earthing terminal stipulated in safety standards is used. Electric shock or malfunction may occur if ground is not connected properly.

# ? SERVICE DETAILS

This power supply is not field serviceable product. In case of failure or malfunction, send back the power supply to factory.

Please contact service center for repair on the following numbers:

Tel. No. : +91-7498077172; Email : service@selec.com

NO WARRANTY ON UNIT DAMAGED DUE TO WRONG CONNECTION OF POWER SUPPLY.

(Specifications are subject to change, since development is a continuous process.)

Factory Address :

EL-27/1, Electronic Zone, TTC Industrial Area, MIDC, Mahape, Navi Mumbai - 400 710, INDIA.

Tel. No.: +91-22-28476443 / 1882

Fax No.: +91-22-28471733 | Toll free: 1800 227 353 | Website: www.selec.com | Email: sales@selec.com